


BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S



- On-Machine™ compact fieldbus I/O blocks
- EtherNet/IP™, Modbus® TCP or PROFINET slave
- Integrated Ethernet switch
- 10 Mbps/100 Mbps supported
- Two 4-pin, D-coded M12 connectors for fieldbus connection
- 2 rotary coding switches for node-address
- IP 69K
- M12 I/O ports
- LEDs indicating status and diagnostics
- Electronics galvanically isolated from the field level via optocouplers
- Simple RFID interface
- Connection of 4 BL ident read/write heads
- Max. cable length 50 m
- FLC/ARGEE programmable

Type designation	BLCEN-4M12LT-2RFID-S-2RFID-S
Ident no.	6811453
Nominal system voltage	24 VDC
System power supply	Via auxiliary power
Voltage supply connection	2 x M12, 5-pin
Admissible range Vi	18...30VDC
Nominal current Vi	175 mA
Max. current Vi	2 A
Fieldbus transmission rate	10/100 Mbps
Adjustment transmission rate	Automatic detection
Fieldbus address range	1...92 0 (192.168.1.254) 93 (BootP) 94 (DHCP) 95 (PGM) 96 (PGM-DHCP) *Recommended for PROFINET 97...98 (manufacturer specific)
Fieldbus addressing	2 dec. Rotary coding switches
Fieldbus connection technology	2 x M12 4-pin, D-coded
Protocol detection	automatic
Web server	Integrated
Service interface	Ethernet
Vendor ID	48
Product type	12
Product code	11453
Modbus TCP	
Addressing	Static IP, BOOTP, DHCP
Supported function codes	FC1, FC2, FC3, FC4, FC5, FC6, FC15, FC16, FC23
Number of TCP connections	6
Input Data Size	max. 26 register
Input register start address	0 (0x0000 hex)
Output Data Size	max. 24 register
Output register start address	2048 (0x0800 hex)
EtherNet/IP™	
Addressing	acc. to EtherNet/IP™ specification
Device Level Ring (DLR)	supported
Class 1 connections (CIP)	6
Input Assembly Instance	103
Input Data Size	27 INT
Output Assembly Instance	104
Output Data Size	24 INT
Configuration Assembly Instance	106
Configuration Size	0
Comm Format	Data - INT

**BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S**

PROFINET

Addressing	DCP
Conformance class	B (RT)
MinCycleTime	1 ms
Diagnostics	acc. to PROFINET alarm handling
Topology detection	supported
Automatic addressing	supported
Media Redundancy Protocol (MRP)	supported
Input Data Size	max. 48 BYTE
Output Data Size	max. 48 BYTE

Technology

Signal type	Simple RFID interface
Number of channels	4
Sensor supply	0.5 A per channel, short-circuit proof
Simultaneity factor	1
Transmission rate	115.2 kbps
Cable length	50 m
Electrical isolation	Electronics and field level isolated via optocouplers

Dimensions

Mounting	168 x 71 x 32.5 mm
Weight	2 x 5.4 mm diameter holes, 1.7 Nm torque
Housing material	530 ± 20 g
Housing color	Glass fiber reinforced nylon, nickel-plated connector
Window material	Black
Material screw	Lexan
Material label	Nickel-plated brass
Ground label material	Polyester with polycarbonate overlay
Protection class	Nickel-plated brass
	IP67
	IP69K
Operating temperature	-40...+70 °C
Storage temperature	-40...+85 °C
Relative humidity	15 to 95% (non-condensing)
Vibration test	acc. to IEC 61131-2
Extended vibration resistance - up to 20 g (at 10 up to 150 Hz)	For mounting on base plate or machinery
Shock test	acc. to IEC 61131-2
Electromagnetic compatibility	acc. to IEC 61131-2
MTTF	104 years
MTTF note	acc. to SN 29500 (Ed. 99) 20 °C
Approvals and certificates	CE, cULus, Class I Div.2

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

	<p>Ethernet Fieldbus cable (IP67 example): RSSD RSSD 441-2M ID number U-02482 or RSSD-RSSD-441-2M/S2174 ID number 6914218</p>	<p>Pin assignment (M12, D-coded)</p>
	<p>Slot 1: RFID Channels Extension cable (example): RK 4.5T-2-RS 4.5T/S2501 ident-no. U3-01243 or RK4.5T-2-RS4.5T/S2500 ident-no. 6699200</p>	<p>.../S2500 Connectors</p>
	<p>Slot 2: RFID Channels See slot 1</p>	<p>.../S2501 Connectors</p>
	<p>Auxiliary Power Extension cable (example): RKC 4.4T-2-RSC 4.4T ident-no. U5264 or RKC4.4T-2-RSC4.4T/TEL ident-no. 6625208</p>	<p>Pin Assignment</p>

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

Status: Station LED

LED	Color	Status	Description
IOs		OFF	Power off
	RED	ON	Insufficient power supply
	RED	FLASHING (1Hz)	Deviating station configuration
	RED	FLASHING (4 Hz)	No module bus communication
	GREEN	ON	Station OK
	GREEN	FLASHING	Force mode active
BUS		OFF	Power Off
	GREEN	ON	Connected to Master
	GREEN	FLASHING	Ready
	RED	ON	Error
	RED	FLASHING	WINK
	YELLOW	ON	DHCP/BOOTP Search
IO	GREEN	ON	I/O slots OK
	GREEN	FLASHING (1Hz)	At least one I/O slot in idle state
	RED	ON	At least one faulty I/O slot
	RED	FLASHING	At least one I/O slot in faulty state

Status: I/O LED, slot 1

LED	Color	Status	Description
D1 *		OFF	Diagnostic disabled
	RED	ON	Station / module bus communication failure
	RED	FLASHING (0.5Hz)	Summarized diagnostic
RW0 / RW1		OFF	No tag, diagnostic disabled
	GREEN	ON	Tag available
	GREEN	FLASHING (2 Hz)	Data exchange with tag enabled
	RED	ON	Read/write head fault
	RED	FLASHING (2 Hz)	Short-circuit in the supply line of read/write head

* D1 LED also indicates gateway diagnostic

I/O LED Status Slot 2

LED	Colour	Status	Description
D2 *		OFF	Diagnostic disabled
	RED	ON	Station / module bus communication failure
	RED	FLASHING (0.5Hz)	Summarized diagnostic
RW0 / RW1		OFF	No tag, no active diagnostics
	GREEN	ON	Tag available
	GREEN	FLASHING (2 Hz)	Data transfer from/to tag active
	RED	ON	Read/write head error
	RED	FLASHING (2 Hz)	Short-circuit in transceiver feed

* The D2 LED also indicates gateway diagnosis

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

Process Data Mapping of the Single Protocols

EtherNet/IP™ I/O and Diagnostic Data Mapping

INPUT	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	
RFID 1 ₀	0	Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	1	Error Cat. (Category Code)								
	2	Error Desc. (Description Code)								
	3	-	-	-	-	-	-	-	-	-
	4...11	Read Data (8 Byte)								
RFID 1 ₁	12	Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	13	Error Cat. (Category Code)								
	14	Error Desc. (Description Code)								
	15	-	-	-	-	-	-	-	-	-
	16...23	Read Data (8 Byte)								
RFID 2 ₀	24	Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	25	Error Cat. (Category Code)								
	26	Error Desc. (Description Code)								
	27	-	-	-	-	-	-	-	-	-
	28...35	Read Data (8 Byte)								
RFID 2 ₁	36	Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	37	Error Cat. (Category Code)								
	38	Error Desc. (Description Code)								
	39	-	-	-	-	-	-	-	-	-
	40...47	Read Data (8 Byte)								
Diagnose	48	Modulnummer meldet Diagnose Daten								
	49	Austauschstation	-	Diagnose aktiv	-	-	-	-	-	
Steckplatz X (Ref. Byte 48)	50	-	-	-	-	-	RFID X ₀ Trans. PS Off	-	-	
	51	-	-	-	-	RFID X ₀ Trans. PS Error	-	RFID X ₀ Trans. Hardware-Fehler		
	52	-	-	-	-	-	RFID X ₁ Trans. PS Off	-	-	
	53	-	-	-	-	RFID X ₁ Trans. PS Error	-	RFID X ₁ Trans. Hardware-Fehler		
OUTPUT	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	
RFID 1 ₀	0	Transceiver	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
	1	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0	
	2	Address High Byte (MSB)								
	3	Address Low Byte (LSB)								
	4...11	Write Data (8 Byte)								
RFID 1 ₁	12	Transceiver	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
	13	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0	
	14	Address High Byte (MSB)								
	15	Address Low Byte (LSB)								
	16...23	Write Data (8 Byte)								
RFID 2 ₀	24	Transceiver	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
	25	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0	
	26	Address High Byte (MSB)								
	27	Address Low Byte (LSB)								
	28...35	Write Data (8 Byte)								
RFID 2 ₁	36	Transceiver	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
	37	-	-	-	-	-	Byte Count 2	Byte Count 1	Byte Count 0	
	38	Address High Byte (MSB)								
	39	Address Low Byte (LSB)								
	40...47	Write Data (8 Byte)								

* If both slots of the module are diagnosable, the display of continuous diagnostic (scheduled diagnostic) switches every 125 ms between slot 1 and 2.

Modbus TCP Register Mapping

	REG	Bit 15	Bit 14	Bit 13	Bit 12	Bit 11	Bit 10	Bit 9	Bit 8	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
--	-----	--------	--------	--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

Eingänge (RO)	0x0000	Error Cat. (Category Code)								Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	0x0001	-	-	-	-	-	-	-	-	Error Desc. (Description Code)								
	0x0002 ... 0x0005	Read Data (4 Words)																
	0x0006	Error Cat. (Category Code)								Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	0x0007	-	-	-	-	-	-	-	-	Error Desc. (Description Code)								
	0x0008 ... 0x000B	Read Data (4 Words)																
	0x000C	Error Cat. (Category Code)								Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	0x000D	-	-	-	-	-	-	-	-	Error Desc. (Description Code)								
	0x000E ... 0x0011	Read Data (4 Words)																
	0x0012	Error Cat. (Category Code)								Done	Busy	Fehler	Trans. Conn.	Trans. On	TP	TFR	-	
	0x0013	-	-	-	-	-	-	-	-	Error Desc. (Description Code)								
	0x0014 ... 0x0017	Read Data (4 Words)																
	Status (RO)	0x0018	-	FCE	-	-	CFG	COM	VI low	-	VO low	-	-	-	-	-	-	DIA
	Diag. (RO)	0x0019	-	-	-	-	-	-	-	-	-	-	-	-	-	-	S2 DIA	S1 DIA
	Ausgänge (RW)	0x0800	-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset
		0x0801	Address															
		0x0802 ... 0x0805	Write Data (4 Words)															
0x0806		-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
0x0807		Address																
0x0808 ... 0x080B		Write Data (4 Words)																
0x080C		-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
0x080D		Address																
0x080E ... 0x0811		Write Data (4 Words)																
0x0812		-	-	-	-	-	Byte CNT 2	Byte CNT 1	Byte CNT 0	Trans.	Next	TAG ID	Read	Write	TAG Info	Trans. Info.	Reset	
0x0813		Address																
0x0814 ... 0x0817		Write Data (4 Words)																
I/O Diag (RO)		0xA000	-	-	-	-	PS RFID 1 ₀	-	-	HW RFID 1 ₀	-	-	-	-	-	SCO RFID 1 ₀	-	-
		0xA001	-	-	-	-	PS RFID 1 ₁	-	-	HW RFID 1 ₁	-	-	-	-	-	SCO RFID 1 ₁	-	-
		0xA002	-	-	-	-	PS RFID 2 ₀ PS RFID 1 ₀	-	-	HW RFID 2 ₀	-	-	-	-	-	SCO RFID 2 ₀	-	-
		0xA003	-	-	-	-	PS RFID 2 ₁	-	-	HW RFID 2 ₁	-	-	-	-	-	SCO RFID 2 ₁	-	-

PROFINET® Process Data


	BYTE	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Eingänge	0	RFID 1 ₀ Done	RFID 1 ₀ Busy	RFID 1 ₀ Fehler	RFID 1 ₀ Trans. Conn.	RFID 1 ₀ Trans. On	RFID 1 ₀ TP	RFID 1 ₀ TFR	-
	1	RFID 1 ₀ Error Cat. (Category Code)							
	2	RFID 1 ₀ Error Desc. (Description Code)							
	3	-	-	-	-	-	-	-	-
	4...11	RFID 1 ₀ Read Data (8 Byte)							
	12	RFID 1 ₁ Done	RFID 1 ₁ Busy	RFID 1 ₁ Fehler	RFID 1 ₁ Trans. Conn.	RFID 1 ₁ Trans. On	RFID 1 ₁ TP	RFID 1 ₁ TFR	-

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident® Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

	13	RFID 1, Error Cat. (Category Code)								
	14	RFID 1, Error Desc. (Description Code)								
	15	-	-	-	-	-	-	-		
	16...23	RFID 1, Read Data (8 Byte)								
	24	RFID 2, Done	RFID 2, Busy	RFID 2, Fehler	RFID 2, Trans. Conn.	RFID 2, Trans. On	RFID 2, TP	RFID 2, TFR	-	
	25	RFID 2, Error Cat. (Category Code)								
	26	RFID 2, Error Desc. (Description Code)								
	27	-	-	-	-	-	-	-		
	28...35	RFID 2, Read Data (8 Byte)								
	36	RFID 2, Done	RFID 2, Busy	RFID 2, Fehler	RFID 2, Trans. Conn.	RFID 2, Trans. On	RFID 2, TP	RFID 2, TFR	-	
	37	RFID 2, Error Cat. (Category Code)								
	38	RFID 2, Error Desc. (Description Code)								
	39	-	-	-	-	-	-	-		
	40...47	RFID 2, Read Data (8 Byte)								
Outputs	0	RFID 1, Transceiver	RFID 1, Next	RFID 1, TAG ID	RFID 1, Read	RFID 1, Write	RFID 1, TAG Info	RFID 1, Trans. Info.	RFID 1, Reset	
	1	-	-	-	-	-	RFID 1, Byte Count 2	RFID 1, Byte Count 1	RFID 1, Byte Count 0	
	2	RFID 1, Address High Byte (MSB)								
	3	RFID 1, Address Low Byte (LSB)								
	4...11	RFID 1, Write Data (8 Byte)								
	12	RFID 1, Transceiver	RFID 1, Next	RFID 1, TAG ID	RFID 1, Read	RFID 1, Write	RFID 1, TAG Info	RFID 1, Trans. Info.	RFID 1, Reset	
	13	-	-	-	-	-	RFID 1, Byte Count 2	RFID 1, Byte Count 1	RFID 1, Byte Count 0	
	14	RFID 1, Address High Byte (MSB)								
	15	RFID 1, Address Low Byte (LSB)								
	16...21	RFID 1, Write Data (8 Byte)								
	24	RFID 2, Transceiver	RFID 2, Next	RFID 2, TAG ID	RFID 2, Read	RFID 2, Write	RFID 2, TAG Info	RFID 2, Trans. Info.	RFID 2, Reset	
	25	-	-	-	-	-	RFID 2, Byte Count 2	RFID 2, Byte Count 1	RFID 2, Byte Count 0	
	26	RFID 2, Address High Byte (MSB)								
	27	RFID 2, Address Low Byte (LSB)								
	28...33	RFID 2, Write Data (8 Byte)								
	36	RFID 2, Transceiver	RFID 2, Next	RFID 2, TAG ID	RFID 2, Read	RFID 2, Write	RFID 2, TAG Info	RFID 2, Trans. Info.	RFID 2, Reset	
	37	-	-	-	-	-	RFID 2, Byte Count 2	RFID 2, Byte Count 1	RFID 2, Byte Count 0	
	38	RFID 2, Address High Byte (MSB)								
	39	RFID 2, Address Low Byte (LSB)								
	40...47	RFID 2, Write Data (8 Byte)								

BL compact Multiprotocol Station for Industrial Ethernet
Interface for Connection of 4 BL ident[®] Read/Write Heads (HF/UHF)
BLCEN-4M12LT-2RFID-S-2RFID-S

Accessories

Type code	Ident no.	Description	Dimension drawing
LOCK-EURO-C	A0885	Locking guard for straight eurofast™ C-body connectors (RKC, RKCV, RSC, RSCV) in a Class I, Division 2 installations	
LOCK-EURO-C (10/BAG)	A0886	Locking guard for straight eurofast™ C-body connectors (RKC, RKCV, RSC, RSCV) in a Class I, Division 2 installations	